

# ANNUAL REPORT

## ERIN DRINKING WATER SYSTEM

FOR THE PERIOD:  
JANUARY 1, 2021 – DECEMBER 31, 2021

*Prepared for the Town of Erin  
by the Ontario Clean Water Agency*



**ONTARIO CLEAN WATER AGENCY**  
**AGENCE ONTARIENNE DES EAUX**

<b>Drinking-Water System Number:</b>	220000013
<b>Drinking-Water System Name:</b>	Erin Drinking Water System
<b>Drinking-Water System Owner:</b>	The Corporation of the Town of Erin
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2021 – December 31, 2021

<u><b>Complete if your Category is Large Municipal Residential or Small Municipal Residential</b></u>	<u><b>Complete for all other Categories.</b></u>
<p><b>Does your Drinking-Water System serve more than 10,000 people?</b>                      Yes [ ] No [X]</p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet?</b>                      Yes [X] No [ ]</p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b>                      Office of the Town of Erin                      5684 Trafalgar Road                      Hillsburgh, Ontario                      N0B 1Z0</p>	<p><b>Number of Designated Facilities served:</b>                      Not Applicable</p> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve?</b>                      Not Applicable</p> <p><b>Number of Interested Authorities you report to:</b>                      Not Applicable</p> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?</b>                      Not Applicable</p>

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
<i>Not Applicable</i>	<i>Not Applicable</i>

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

*Not Applicable*

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method:

### **Describe your Drinking-Water System**

The Erin Drinking Water System is a Class 3 Water Distribution and Supply Subsystem serving a population of approximately 3000 residential and commercial customers, located in the former Village of Erin. The distribution system has 26 km of water mains with 154 fire hydrants.

The water system is a ground water system supplied from two wells drilled into the fractured limestone bedrock, with a total rated capacity of 4,128 m<sup>3</sup>/day. The pressure in most of the Erin Drinking Water System is maintained by a 1,703 m<sup>3</sup> water tower, however 65 residences in the Erin Heights Subdivision require a booster pump to maintain adequate pressure.

Well No. 7, located at 46 Shamrock Road (9555 Side Road 17), Erin, is a 260 mm diameter, 43m deep drilled ground water well, with casing to a depth of 19.1m. The well is located inside the pump house and is equipped with a submersible pump rated at 1,800 L/min. The neighboring land is used for both industrial and agricultural purposes. There is also undeveloped land in the vicinity of the Pumphouse.

Well No. 8, located on Lot 17, concession 8-9 (5555 Eighth Line), Erin, is a 200 mm diameter, 46 m deep drilled groundwater well, with double casing to depths of 6.7 m (outer casing) and 8.53 m (inner casing). The well is located approximately 4 m northwest of the pump house and is equipped with a submersible pump rated at 1,636 L/min. The neighboring land is used for both residential and agricultural purposes. A golf course runs adjacent to the Pumphouse along with undeveloped land.

### **List all water treatment chemicals used over this reporting period**

- Gaseous Chlorine NSF, Disinfection

### **Were any significant expenses incurred to?**

- |                                     |                                       |
|-------------------------------------|---------------------------------------|
| <input checked="" type="checkbox"/> | Install required equipment            |
| <input checked="" type="checkbox"/> | Repair required equipment             |
| <input checked="" type="checkbox"/> | Replace required equipment            |
| <input type="checkbox"/>            | No significant expenses were incurred |

### **Please provide a brief description of any significant expenses incurred**

- Annual Flow Meter Calibrations
- Annual Generator Load Testing
- Annual Backflow Preventer Inspections
- DWQMS Systems Audit
- Well E8 New Radio For Communication Installed
- Reservoir Transducer Calibration
- Datalogger Replacements
- Gas Sensor Replacement
- Hydrant Repair and Maintenance
- Distribution Service Repairs
- Water Meter Residential Replacements

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date (yyyy/mm/dd)	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date (yyyy/mm/dd)
n/a	n/a	n/a	n/a	n/a	n/a

**Table 1. Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

Location	Number of Samples	Range of E.coli Results		Range of Total Coliforms Results		Number of HPC Samples	Range of HPC Samples	
		Min.	Max.	Min.	Max.		Min.	Max.
Raw Water - Well E7	52	0	0	0	0	0	-	-
Raw Water - Well E8	52	0	0	0	0	0	-	-
Treated Water – E7	52	0	0	0	0	52	0	42
Treated Water – E8	52	0	0	0	0	52	0	56
Distribution	210	0	0	0	0	212	0	43

**Table 2. Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.**

Parameter	Number of Grab Samples	Range of Results	
		Minimum	Maximum
<b>Raw Water</b>			
Turbidity, Well E7 (NTU)	12	0.11	0.53
Turbidity, Well E8 (NTU)	12	0.04	0.52
<b>Treated Water</b>			
Free Chlorine Residual, TW E7 (mg/L)	8760	0.002*	2.00
Free Chlorine Residual, TW E8 (mg/L)	8760	0.00*	2.00
<b>Distribution Water</b>			
Free Chlorine Residual, DW (mg/L)	8760	0.00*	5.00**

NOTE: For continuous monitors, 8760 is used as the number of samples.

\*Minimum chlorine residuals of 0 mg/L are due to analyzer calibrations, analyzer maintenance and data logger install; actual readings at the time were well within regulatory requirements.

\*\*Maximum chlorine residual of 5 mg/L due to analyzer calibrations/maintenance; actual readings at the time were well within regulatory requirements.

**Table 3. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
<i>Not Applicable</i>				

**Table 4. Summary of Inorganic parameters tested during this reporting period or most recent sample results**

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances – Yes/No	
				MAC	1/2 MAC
Antimony: Sb (µg/L) – TW E7	2021/05/18	0.5	6.0	No	No
Antimony: Sb (µg/L) – TW E8	2021/05/18	0.5	6.0	No	No
Arsenic: As (µg/L) - TW E7	2021/05/18	1.0	10.0	No	No
Arsenic: As (µg/L) – TW E8	2021/05/18	1.0	10.0	No	No
Barium: Ba (µg/L) - TW E7	2021/05/18	34.0	1000.0	No	No
Barium: Ba (µg/L) – TW E8	2021/05/18	47.0	1000.0	No	No
Boron: B (µg/L) - TW E7	2021/05/18	17.0	5000.0	No	No
Boron: B (µg/L) – TW E8	2021/05/18	13.0	5000.0	No	No
Cadmium: Cd (µg/L) - TW E7	2021/05/18	0.09	5.0	No	No
Cadmium: Cd (µg/L) – TW E8	2021/05/18	0.09	5.0	No	No
Chromium: Cr (µg/L) - TW E7	2021/05/18	5.0	50.0	No	No
Chromium: Cr (µg/L) – TW E8	2021/05/18	5.0	50.0	No	No
Mercury: Hg (µg/L) - TW E7	2021/05/18	0.1	1.0	No	No
Mercury: Hg (µg/L) – TW E8	2021/05/18	0.1	1.0	No	No
Selenium: Se (µg/L) - TW E7	2021/05/18	2.0	50.0	No	No
Selenium: Se (µg/L) – TW E8	2021/05/18	2.0	50.0	No	No
Uranium: U (µg/L) - TW E7	2021/05/18	0.49	20.0	No	No
Uranium: U (µg/L) - TW E8	2021/05/18	0.17	20.0	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) – TW E7	2018/05/09	0.20	1.5	No	No
Fluoride (mg/L) – TW E8	2018/05/09	0.26	1.5	No	No
Nitrite (mg/L) - TW7	2021/01/05	0.01	1.0	No	No
Nitrite (mg/L) - TW7	2021/04/23	0.01	1.0	No	No
Nitrite (mg/L) - TW7	2021/07/06	0.01	1.0	No	No
Nitrite (mg/L) - TW7	2021/10/13	0.01	1.0	No	No
Nitrite (mg/L) - TW8	2021/01/05	0.01	1.0	No	No
Nitrite (mg/L) - TW8	2021/04/23	0.01	1.0	No	No
Nitrite (mg/L) - TW8	2021/07/06	0.01	1.0	No	No
Nitrite (mg/L) - TW8	2021/10/13	0.01	1.0	No	No
Nitrate (mg/L) - TW7	2021/01/05	0.1	10.0	No	No
Nitrate (mg/L) - TW7	2021/04/23	0.13	10.0	No	No
Nitrate (mg/L) - TW7	2021/07/06	0.11	10.0	No	No
Nitrate (mg/L) - TW7	2021/10/13	0.11	10.0	No	No
Nitrate (mg/L) - TW8	2021/01/05	0.1	10.0	No	No
Nitrate (mg/L) - TW8	2021/04/23	0.1	10.0	No	No
Nitrate (mg/L) - TW8	2021/07/06	0.1	10.0	No	No

Nitrate (mg/L) - TW8	2021/10/13	0.1	10.0	No	No
Sodium: Na (mg/L) – TW E7	2021/05/18	7.3	20*	No	No
Sodium: Na (mg/L) – TW E8	2021/05/18	5.3	20*	No	No

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

**Table 5. Summary of lead testing under Schedule 15.1 during this reporting period (applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)**

Location Type	Number of Samples	Range of Results		MAC	Number of Exceedances
		Minimum	Maximum		
Distribution - Lead Results (µg/L)	n/a	n/a	n/a	10	n/a
Distribution - Alkalinity (mg/L)	6	210	220	n/a	n/a
Distribution - pH In-House	6	7.2	8.0	n/a	n/a

*Distribution lead samples are taken every 36 months, last set of lead sampling was completed in September 2019. Next set of lead sampling is scheduled for January 2022.*

The Erin Drinking Water System qualifies for plumbing exemption.

**Table 6. Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances – Yes/No	
				MAC	1/2 MAC
Alachlor (ug/L) - TW7	2021/05/18	0.5	5.0	No	No
Alachlor (ug/L) - TW8	2021/05/18	0.5	5.0	No	No
Azinphos-methyl (ug/L) - TW7	2021/05/18	2.0	20.0	No	No
Azinphos-methyl (ug/L) - TW8	2021/05/18	2.0	20.0	No	No
Benzene (ug/L) - TW7	2021/05/18	0.1	1.0	No	No
Benzene (ug/L) - TW8	2021/05/18	0.1	1.0	No	No
Benzo(a)pyrene (ug/L) - TW7	2021/05/18	0.005	0.01	No	No
Benzo(a)pyrene (ug/L) - TW8	2021/05/18	0.005	0.01	No	No
Bromoxynil (ug/L) - TW7	2021/05/18	0.5	5.0	No	No
Bromoxynil (ug/L) - TW8	2021/05/18	0.5	5.0	No	No
Carbaryl (ug/L) - TW7	2021/05/18	5.0	90.0	No	No
Carbaryl (ug/L) - TW8	2021/05/18	5.0	90.0	No	No
Carbofuran (ug/L) - TW7	2021/05/18	5.0	90.0	No	No
Carbofuran (ug/L) - TW8	2021/05/18	5.0	90.0	No	No
Carbon Tetrachloride (ug/L) - TW7	2021/05/18	0.1	2.0	No	No
Carbon Tetrachloride (ug/L) - TW8	2021/05/18	0.1	2.0	No	No
Chlorpyrifos (ug/L) - TW7	2021/05/18	1.0	90.0	No	No

Chlorpyrifos (ug/L) - TW8	2021/05/18	1.0	90.0	No	No
Diazinon (ug/L) - TW7	2021/05/18	1.0	20.0	No	No
Diazinon (ug/L) - TW8	2021/05/18	1.0	20.0	No	No
Dicamba (ug/L) - TW7	2021/05/18	1.0	120.0	No	No
Dicamba (ug/L) - TW8	2021/05/18	1.0	120.0	No	No
1,2-Dichlorobenzene (ug/L) - TW7	2021/05/18	0.2	200.0	No	No
1,2-Dichlorobenzene (ug/L) - TW8	2021/05/18	0.2	200.0	No	No
1,4-Dichlorobenzene (ug/L) - TW7	2021/05/18	0.2	5.0	No	No
1,4-Dichlorobenzene (ug/L) - TW8	2021/05/18	0.2	5.0	No	No
1,2-Dichloroethane (ug/L) - TW7	2021/05/18	0.2	5.0	No	No
1,2-Dichloroethane (ug/L) - TW8	2021/05/18	0.2	5.0	No	No
1,1-Dichloroethylene (ug/L) - TW7	2021/05/18	0.1	14.0	No	No
1,1-Dichloroethylene (ug/L) - TW8	2021/05/18	0.1	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW7	2021/05/18	0.5	50.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW8	2021/05/18	0.5	50.0	No	No
2,4-Dichlorophenol (ug/L) - TW7	2021/05/18	0.25	900.0	No	No
2,4-Dichlorophenol (ug/L) - TW8	2021/05/18	0.25	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW7	2021/05/18	1.0	100.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW8	2021/05/18	1.0	100.0	No	No
Diclofop-methyl (ug/L) - TW7	2021/05/18	0.9	9.0	No	No
Diclofop-methyl (ug/L) - TW8	2021/05/18	0.9	9.0	No	No
Dimethoate (ug/L) - TW7	2021/05/18	2.5	20.0	No	No
Dimethoate (ug/L) - TW8	2021/05/18	2.5	20.0	No	No
Diquat (ug/L) - TW7	2021/05/18	7.0	70.0	No	No
Diquat (ug/L) - TW8	2021/05/18	7.0	70.0	No	No
Diuron (ug/L) - TW7	2021/05/18	10.0	150.0	No	No
Diuron (ug/L) - TW8	2021/05/18	10.0	150.0	No	No
Glyphosate (ug/L) - TW7	2021/05/18	10.0	280.0	No	No
Glyphosate (ug/L) - TW8	2021/05/18	10.0	280.0	No	No
Malathion (ug/L) - TW7	2021/05/18	5.0	190.0	No	No
Malathion (ug/L) - TW8	2021/05/18	5.0	190.0	No	No
Metolachlor (ug/L) - TW7	2021/05/18	0.5	50.0	No	No
Metolachlor (ug/L) - TW8	2021/05/18	0.5	50.0	No	No
Metribuzin (ug/L) - TW7	2021/05/18	5.0	80.0	No	No
Metribuzin (ug/L) - TW8	2021/05/18	5.0	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW7	2021/05/18	0.1	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW8	2021/05/18	0.1	80.0	No	No
Paraquat (ug/L) - TW7	2021/05/18	1.0	10.0	No	No
Paraquat (ug/L) - TW8	2021/05/18	1.0	10.0	No	No
PCB (ug/L) - TW7	2021/05/18	0.05	3.0	No	No
PCB (ug/L) - TW8	2021/05/18	0.05	3.0	No	No
Pentachlorophenol (ug/L) - TW7	2021/05/18	0.5	60.0	No	No

Pentachlorophenol (ug/L) - TW8	2021/05/18	0.5	60.0	No	No
Phorate (ug/L) - TW7	2021/05/18	0.5	2.0	No	No
Phorate (ug/L) - TW8	2021/05/18	0.5	2.0	No	No
Picloram (ug/L) - TW7	2021/05/18	5.0	190.0	No	No
Picloram (ug/L) - TW8	2021/05/18	5.0	190.0	No	No
Prometryne (ug/L) - TW7	2021/05/18	0.25	1.0	No	No
Prometryne (ug/L) - TW8	2021/05/18	0.25	1.0	No	No
Simazine (ug/L) - TW7	2021/05/18	1.0	10.0	No	No
Simazine (ug/L) - TW8	2021/05/18	1.0	10.0	No	No
Terbufos (ug/L) - TW7	2021/05/18	0.5	1.0	No	No
Terbufos (ug/L) - TW8	2021/05/18	0.5	1.0	No	No
Tetrachloroethylene (ug/L) - TW7	2021/05/18	0.1	10.0	No	No
Tetrachloroethylene (ug/L) - TW8	2021/05/18	0.1	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW7	2021/05/18	0.5	100.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW8	2021/05/18	0.5	100.0	No	No
Triallate (ug/L) - TW7	2021/05/18	1.0	230.0	No	No
Triallate (ug/L) - TW8	2021/05/18	1.0	230.0	No	No
Trichloroethylene (ug/L) - TW7	2021/05/18	0.1	5.0	No	No
Trichloroethylene (ug/L) - TW8	2021/05/18	0.1	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW7	2021/05/18	0.5	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW8	2021/05/18	0.5	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L) - TW7	2021/05/18	10.0	100.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L) - TW8	2021/05/18	10.0	100.0	No	No
Trifluralin (ug/L) - TW7	2021/05/18	1.0	45.0	No	No
Trifluralin (ug/L) - TW8	2021/05/18	1.0	45.0	No	No
Vinyl Chloride (ug/L) - TW7	2021/05/18	0.2	1.0	No	No
Vinyl Chloride (ug/L) - TW8	2021/05/18	0.2	1.0	No	No
<b>Distribution Water</b>					
Trihalomethane: Total (µg/L) Annual Average - DW	2021 (Quarterly)	4.695	100.00	No	No
HAA Total (µg/L) Annual Average - DW	2021 (Quarterly)	5.00	80.00	No	No

**Table 7. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. (Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non-municipal year round residential, large non municipal non-residential)**

Parameter	Result Value	Unit of Measure	Date of Sample
<i>Not Applicable</i>			